



KEYED NOTES - LIGHTING PLAN	
MARK	DESCRIPTION
1	PROVIDE ON-OFF SWITCH SINCE THIS AREA IS PART OF EMERGENCY EGRESS CORRIDOR IN ACCORDANCE WITH EXCEPTIONS IN IECC.
2	LIGHTS ON THIS SWITCH SHALL BE DOUBLE BALLASTED.
3	PROVIDE MOTION DETECTOR FOR THIS ROOM LIGHTING TO BE ACTIVATED WITH MANUAL SWITCHING OVER-RIDE
4	PROVIDE SEPARATE CONCEALED CONDUIT FOR DC SERVICE FROM INTERIOR BATTERY SUPPLY TO EXTERIOR EMERGENCY LIGHT FIXTURE. SEAL EXTERIOR WALL PENETRATION WEATHER-TIGHT.
5	PROVIDE CONCEALED CONDUITS FOR LIGHTS TO PROPOSED AND FUTURE CANOPIES. ROUTE CONDUITS UNDERGROUND AND COORDINATE WITH ARCHITECT TO CONCEAL WITHIN CANOPY STRUCTURE.

Mercator Office Warehouse

20102 Franz Road
Harris County
Katy TX 77449

Project No. 10009
Issue date: xx-xx-15

Revisions:

- 1 Revision
- 2 Revision
- 3 Revision
- 4 Revision
- 5 Revision
- 6 Revision
- 7 Revision
- 8 Revision

ENGINEERING BY:
QUEST ENGINEERING
304 North Main Street #1
Conroe, Texas 77301
Phone: (713) 252-3729
rsaikowski@consolidated.net
Ronald A Saikowski PE LEEP AP 2015
TEXAS REGISTRATION NO. FOR ENGINEERING FIRM IS F-10574



I, RON A. SAIKOWSKI, P.E., AUTHORIZED THE PLACEMENT OF THIS SEAL ON THIS DRAWING FOR THE PURPOSE OF ISSUING THIS DOCUMENT AS SPECIFIED BELOW

<input type="checkbox"/>	Not For Construction
<input type="checkbox"/>	For Background Use Only
<input type="checkbox"/>	Preliminary
<input type="checkbox"/>	For Concept Approval
<input type="checkbox"/>	Preliminary Bid Set
<input type="checkbox"/>	For Preliminary Approval
<input type="checkbox"/>	Permit
<input checked="" type="checkbox"/>	For Final Approval
<input type="checkbox"/>	Check Set
<input type="checkbox"/>	For Construction

NOTE:
CONSTRUCTION SHALL NOT PROCEED UNTIL CONTRACTOR HAS OBTAINED ALL PERMITS AND INCORPORATED COMMENTS FROM TEXAS ACCESSIBILITY STANDARDS REVIEW AND PERMITTING ENTITIES IN WORK.

Preliminary
Not for construction
Not for permits
Not for regulatory approval

E 2.0
LIGHTING PLAN